

Rittal – The System.

Faster – better – everywhere.

CERTIFICATE

Rittal quality management

The Rittal Wall angle for AX, KX, AX IT, AE, KL

article No. 2583.010 and 2505.510

- mounted in accordance to the assembly instructions -

does not have impact on the IP rating according to EN 60 529
„Degrees of protection provided by enclosures“ dated September 2014
or the type rating according to UL50E, 3rd ed.
for AX, KX, AX IT, AE and KL enclosures.



Axel Remmert
Quality Management Laboratory

2022-05-24

ENCLOSURES

POWER DISTRIBUTION

CLIMATE CONTROL

IT INFRASTRUCTURE

SOFTWARE & SERVICES

