

CERTIFICATE

issued by

Rittal GmbH & Co. KG

Auf dem Stützelberg
D-35745 Herborn

Quality Management

Hereby we confirm that the wall-mounted enclosures EL

7709.735	7715.735	7721.735
7709.535	7715.535	7721.535

fulfil - in conjunction with solid gland plate on the top and bottom -
the protection category IP54 according to EN 60529 „Degrees of
protection provided by enclosures“ dated September 2014.

Herborn, 2018-04-11


Axel Remmert
Quality Management Laboratory



Rittal's test laboratory is accredited with the German Accreditation
Council (DAkkS) No. D-PL-17086-01-00 and Underwriters Laboratories Inc.

Rittal GmbH & Co. KG
Personally liable:
Rittal Management GmbH,
Schwende

Management:
Dr.-Ing. Karl-Ulrich Köhler (CEO)
Hans Sondermann
Dr. Thomas Steffen
Andreas Huck
Carsten Röttchen

Rittal GmbH & Co. KG
Auf dem Stützelberg
D-35745 Herborn
Phone: +49(0)27 72 5 05-0
Fax: +49(0)27 72 5 05-23 19
E-Mail: info@rittal.de
www.rittal.de
HRA 6126 Wetzlar

ENCLOSURES

POWER DISTRIBUTION

CLIMATE CONTROL

IT INFRASTRUCTURE

SOFTWARE & SERVICES

