

# CERTIFICATE

issued by

**Rittal GmbH & Co. KG**

Auf dem Stützelberg  
D-35745 Herborn

Quality Management

Hereby we confirm that the wall-mounted enclosures EL

7706.135	7709.135	7712.135	7715.135
7721.135	2243.605	2253.605	2246.605
2256.605	2249.605	2259.605	2252.605
2262.605	2255.605	2265.605	2261.605
2271.605	-	-	-

fulfil the protection category IP55 according to EN 60529 „Degrees of protection provided by enclosures“ dated September 2014.

Herborn, 2018-04-11

  
Axel Remmert  
Quality Management Laboratory



Rittal's test laboratory is accredited with the German Accreditation Council (DAkkS) No. D-PL-17086-01-00 and Underwriters Laboratories Inc.

Rittal GmbH & Co. KG  
Personally liable:  
Rittal Management GmbH,  
Schwende

Management:  
Dr.-Ing. Karl-Ulrich Köhler (CEO)  
Hans Sondermann  
Dr. Thomas Steffen  
Andreas Huck  
Carsten Röttchen

Rittal GmbH & Co. KG  
Auf dem Stützelberg  
D-35745 Herborn  
Phone: +49(0)27 72 5 05-0  
Fax: +49(0)27 72 5 05-23 19  
E-Mail: info@rittal.de  
www.rittal.de  
HRA 6126 Wetzlar

ENCLOSURES

POWER DISTRIBUTION

CLIMATE CONTROL

IT INFRASTRUCTURE

SOFTWARE & SERVICES

