

CERTIFICATE OF COMPLIANCE

Certificate Number 20190910-E76083
Report Reference E76083-20190830
Issue Date 2019-SEPTEMBER-10

Issued to: RITTAL GmbH & Co. KG
Auf dem Stuetzelberg
35745 Herborn GERMANY

**This certificate confirms that
representative samples of**

INDUSTRIAL CONTROL PANELS
USL, CNL - Enclosures for Industrial Control Panels,
Enclosure series AX Operating housing.

Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.

Standard(s) for Safety: UL 508A Standard for Industrial Control Panels
CSA C22.2 No. 14-18 Standard for Industrial Control
Equipment

Additional Information: See the UL Online Certifications Directory at
<https://iq.ulprospector.com> for additional information.

This *Certificate of Compliance* does not provide authorization to apply the UL Mark. Only the UL Follow-Up Services Procedure provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

