

CERTIFICATE

issued by

Rittal GmbH & Co. KG

Auf dem Stützelberg
D-35745 Herborn

Quality Management

Herewith we confirm that the Rittal stainless steel enclosures AE 1016.600 comply with the requirements of the Hosedown test according to UL 50 Type 4X (NEMA 4X) and fulfil the protection category IP 66 according to EN 60529 „Degrees of protection provided by enclosures“ dated September 2000.



Herborn, 15.02.2012

Axel R Emmert
Quality Management Laboratory



Rittal's test laboratory is accredited with the German Accreditation Council (DAR) No. DAP-PL-3025.00 and Underwriters Laboratories Inc.

Rittal GmbH & Co. KG
Personally liable:
Rittal Management GmbH,
Schwende

Geschäftsführung:
Friedhelm Loh (President)
Bernd Eckel,
Ralph Lindackers
Dr. Thomas Steffen
Michael Weiher

Rittal GmbH & Co. KG
Auf dem Stützelberg
D-35745 Herborn
Phone: +49(0)27 72 5 05-0
Fax: +49(0)27 72 5 05-23 19
E-Mail: info@rittal.de
www.rittal.de
HRA 6126 Wetzlar



SCHALTSCHRÄNKE

STROMVERTEILUNG

KLIMATISIERUNG

IT-INFRASTRUKTUR

SOFTWARE & SERVICE

FRIEDHELM LOH GROUP