

CERTIFICATE

issued by

Rittal GmbH & Co. KG

Auf dem Stützelberg
D-35745 Herborn

Quality Management

Herewith we confirm that the Rittal AE enclosure

1036.500	1033.500	1034.500	1030.500	1031.500
1380.500	1038.500	1338.500	1045.500	1037.500
1050.500	1350.500	1057.500	1039.500	1339.500
1060.500	1054.500	1360.500	1076.500	1376.500
1058.500	1090.500	1260.500	1077.500	1073.500
1055.500	1180.500	1280.500		

complies with the requirements of the hosedown test according to UL50 Type 4 (NEMA 4) and fulfil the protection category IP66 according to EN 60529 "Degrees of protection provided by enclosures" dated September 2000.

Herborn, 2014-02-03


Axel R Emmert
Quality Management Laboratory



Rittal's test laboratory is accredited with the German Accreditation Council (DAkkS) No. D-PL-17086-01-01 and Underwriters Laboratories Inc.

Rittal GmbH & Co. KG
Personally liable:
Rittal Management GmbH,
Schwende

Management:
Friedhelm Loh (President)
Karl Christoph Caselitz
Dr. Guido Stannek
Dr. Thomas Steffen
Hermann Tetzner
Michael Weiher

Rittal GmbH & Co. KG
Auf dem Stützelberg
D-35745 Herborn
Phone: +49(0)27 72 5 05-0
Fax: +49(0)27 72 5 05-23 19
E-Mail: info@rittal.de
www.rittal.de
HRA 6126 Wetzlar

ENCLOSURES

POWER DISTRIBUTION

CLIMATE CONTROL

IT INFRASTRUCTURE

SOFTWARE & SERVICES

