

CERTIFICATE OF COMPLIANCE

Certificate Number 20141018-E170282
Report Reference E170282-20140813
Issue Date 2014-OCTOBER-18

Issued to: RITTAL CORP
1 RITTAL PL
URBANA OH 43078-5003

This is to certify that representative samples of COMPONENT - INDUSTRIAL CONTROL PANELS
See addendum page

Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety: UL 508A and CSA C22.2 No. 14-13 , Standard for Industrial Control Panels.

Additional Information: See the UL Online Certifications Directory at www.ul.com/database for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's Certification and Follow-Up Service.

Recognized components are incomplete in certain constructional features or restricted in performance capabilities and are intended for use as components of complete equipment submitted for investigation rather than for direct separate installation in the field. The final acceptance of the component is dependent upon its installation and use in complete equipment submitted to UL LLC.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Assistant Chief Engineer, Global Inspection and Field Services

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at www.ul.com/contactus



CERTIFICATE OF COMPLIANCE

Certificate Number 20141018-E170282
Report Reference E170282-20140813
Issue Date 2014-OCTOBER-18

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Model WK, f/b xx, f/b yy, f/b C, suitable for Type 1, 2, 3, 3R, 3S, 4, 5, 12 and 12K applications, where xx can be 5-35 and yy can be 3-23.

Model WK, f/b xx, f/b yy, f/b 4 or 6, suitable for Type 1, 2, 3, 3R, 3RX, 3S, 3SX, 3X, 4, 4X, 5, 12 and 12K applications, where xx can be 5-35 and yy can be 3-23.

FMDC Adapter Plate Accessory Kit, Part numbers 9951155, 9951156, 9951157, 9951158 or 9951159, suitable for Type 1, 2, 5 or 12 applications.



Bruce Mahrenholz, Assistant Chief Engineer, Global Inspection and Field Services

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at www.ul.com/contactus

