



Product Service

# CERTIFICATE

No. B 12 03 12010 004

**Holder of Certificate:** Rittal GmbH & Co. KG

Auf dem Stützelberg  
35745 Herborn  
GERMANY

**Production Facility(ies):**

12010, 17037, 44957, 47487

**Certification Mark:**



**Product:**

Switchgear Cabinets

**Model(s):**

type tested cabinets, empty enclosures  
Series AE, AE-EMV, CP-AE  
CP-AE with tableau front

**Parameters:**

protection degree:	IP 55 two door version IP 66 one door version IP 55 at CP-AE IP 54 at CP-AE with tableau front
material:	series AE sheet steel, stainless steel series AL-EMV AlZn coated
wall thickness:	enclosure 1,2 - 1,5 mm door 1,2 - 3,0 mm
dimensions:	200 x 300 x 120 mm to 1400 x 1600 x 400 mm

**Tested according to:** DIN EN 62208:2005

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition the certification holder must not transfer the certificate to third parties. See also notes overleaf.

**Test report no.:**

713003052

**Date,** 2012-03-20

(Horst Kristen)

Page 1 of 1

