



Certificate of Compliance

Certificate: 1695575

Master Contract: 153184

Project: 70000082

Date Issued: July 4, 2013

Issued to: **Rittal GmbH & Co. KG**
Auf dem Stuetzelberg 18
Herborn, 35745
Germany
Attention: Rüdiger Gilardi

The products listed below are eligible to bear the CSA Mark shown



Nitin Bhople

Issued by: Nitin Bhople

PRODUCTS

CLASS 1211 02 - COMFORT CONDITIONING EQUIPMENT - Air Conditioning Apparatus

Air conditioning apparatus, for use with enclosures, Series SK 3366/3377, models SK3366/3377.110, .210, .510 and SK 3366/3377.610 rated 115 V, 60Hz, single phase; models SK3366/3377.100, .200, .500 and SK 3366/3377.600 rated 230 V, 60Hz single phase, and models SK3366/3377.140, .240, .540 and SK 3366/3377.640 rated 460V, 60Hz, three phase, All with Refrigerant R-134a, design pressure 406 psig.

Notes:

Notes (1): The air conditioning equipment to be used as a component part of another equipment, to cool electronic or mechanical components inside an electrical (enclosure) cabinet. The air conditioning unit, maintain a cabinet to a set temperature between 20°C to 55 °C. The unit will be operated within a maximum outdoor temperature ambient up to 55°C.

APPLICABLE REQUIREMENTS

CAN/CSA-C22.2 No. 236-11 - Heating and Cooling Equipment