

CERTIFICATE OF COMPLIANCE

Certificate Number 20130911-SA8250
Report Reference SA8250-20021104
Issue Date 2013-SEPTEMBER-11

Issued to: RITTAL GMBH & CO KG
AUF DEM STUETZELBERG
35745 HERBORN GERMANY

**This is to certify that
representative samples of**

COMPONENT - AIR CONDITIONERS, SPECIAL
PURPOSE



See Addendum Page

Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.

Standard(s) for Safety: UL 484, Standard for Room Air conditioners
CSA C22.2 No.236, Standard for Heating and Cooling
Equipment

Additional Information: See the UL Online Certifications Directory at
www.ul.com/database for additional information

Only those products bearing the UL Recognized Component Marks for the U.S. and Canada should be considered as being covered by UL's Recognition and Follow-Up Service and meeting the appropriate U.S. and Canadian requirements.

The UL Recognized Component Mark for the U.S. generally consists of the manufacturer's identification and catalog number, model number or other product designation as specified under "Marking" for the particular Recognition as published in the appropriate UL Directory. As a supplementary means of identifying products that have been produced under UL's Component Recognition Program, UL's Recognized Component Mark: , may be used in conjunction with the required Recognized Marks. The Recognized Component Mark is required when specified in the UL Directory preceding the recognitions or under "Markings" for the individual recognitions. The UL Recognized Component Mark for Canada consists of the UL Recognized Mark for Canada:  and the manufacturer's identification and catalog number, model number or other product designation as specified under "Marking" for the particular Recognition as published in the appropriate UL Directory.

Recognized components are incomplete in certain constructional features or restricted in performance capabilities and are intended for use as components of complete equipment submitted for investigation rather than for direct separate installation in the field. The final acceptance of the component is dependent upon its installation and use in complete equipment submitted to UL LLC.

Look for the UL Recognized Component Mark on the product.



William R. Carney, Director, North American Certification Programs
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at www.ul.com/contactus



CERTIFICATE OF COMPLIANCE

Certificate Number 20130911-SA8250
Report Reference SA8250-20021104
Issue Date 2013-SEPTEMBER-11

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Component - Special purpose type room air conditioner, Models SK3302.100, SK3302.110, SK3302.200, SK3302.210, SK3302.300, SK3302.310, SK3302.902, SK3302.903, SK3302.906, SK3302.907



William R. Carney, Director, North American Certification Programs
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at www.ul.com/contactus

