

# CERTIFICATE

issued by

**Rittal GmbH & Co. KG**

Auf dem Stützelberg  
D-35745 Herborn

Quality Management

Herewith we confirm that the Rittal GA Cast aluminium enclosures fulfil the protection category IK 08 according to EN 50102 (IEC 62262) „Degrees of protection provided by enclosures for electrical equipment against external mechanical impacts (IK code)“ dated September 1997.



Herborn, 24.05.2011

Axel R Emmert  
Quality Management Laboratory



Rittal's test laboratory is accredited with the German Accreditation Council (DAR) No. DAP-PL-3025.00 and Underwriters Laboratories Inc.

Rittal GmbH & Co. KG  
Personally liable:  
Rittal Management GmbH,  
Schwende

Geschäftsführung:  
Friedhelm Loh (Vorsitzender)  
Bernd Eckel,  
Ralph Lindackers  
Dr. Thomas Steffen  
Michael Weiher

Rittal GmbH & Co. KG  
Auf dem Stützelberg  
D-35745 Herborn  
Phone: +49(0)27 72 5 05-0  
Fax: +49(0)27 72 5 05-23 19  
E-Mail: info@rittal.de  
www.rittal.de  
HRA 6126 Wetzlar



SCHALTSCHRÄNKE

STROMVERTEILUNG

KLIMATISIERUNG

IT-INFRASTRUKTUR

SOFTWARE & SERVICE

FRIEDHELM LOH GROUP