

# CERTIFICATE

issued by

**Rittal GmbH & Co. KG**

Auf dem Stützelberg  
D-35745 Herborn

Quality Management

Herewith we confirm that the Rittal standard enclosure SE 8 comply with the requirements according to UL 50 Type 12 (NEMA 12) and fulfil the protection category IP 55 according to EN 60529 "Degrees of protection provided by enclosures" dated September 2000.

We also confirm that the Rittal standard enclosure SE 8 fulfil the protection category IK 10 according to EN 50102 (IEC 62262) „Degrees of protection provided by enclosures for electrical equipment against external mechanical impacts (IK code)“ dated September 1997.

Herborn, 24.04.2012

  
Axel Remmert  
Quality Management Laboratory



Rittal's test laboratory is accredited with the German Accreditation Council (DAR) No. DAP-PL-3025.00 and Underwriters Laboratories Inc.

Rittal GmbH & Co. KG  
Personally liable:  
Rittal Management GmbH,  
Schwende

Management:  
Friedhelm Loh (President)  
Karl Cristoph Caselitz  
Bernd Eckel  
Ralph Lindackers  
Dr. Thomas Steffen  
Michael Weiher

Rittal GmbH & Co. KG  
Auf dem Stützelberg  
D-35745 Herborn  
Phone: +49(0)27 72 5 05-0  
Fax: +49(0)27 72 5 05-23 19  
E-Mail: info@rittal.de  
www.rittal.de  
HRA 6126 Wetzlar

ENCLOSURES

POWER DISTRIBUTION

CLIMATE CONTROL

IT INFRASTRUCTURE

SOFTWARE & SERVICES

