

Certificate

No.: B 99 03 12010 114



RittalWerk
Rudolf Loh GmbH & Co. KG
Auf dem Sützelberg
35745 Herborn

with production facility(ies)
12010 17037 35651

is authorized to label the following products with the
certification mark E
as shown in the certification mark list. See also notes overleaf.

Product: Switchgear Cabinets

Model: type tested cabinets, empty enclosures
Series KL and EB
E-Box, Bus-Casing (BG)

Parameters:	version	degree of protection	material
	KL without gland plate	IP 66	sheet steel, stainless steel 1.4301
	KL with gland plate	IP 55	sheet steel
	BG-Bus-housing	IP 55	sheet steel, stainless steel 1.4301
	EB	IP 66	sheet steel
	BG-Bus-housing	IP 65	sheet steel, stainless steel 1.4301
	dimensions:	150 x 150 x 80 mm - 1000 x 600 x 160 mm	
	wall thickness:	enclosure	1,2 - 1,5 mm
		cover/door	1,2 - 1,5 mm

The product meets the relevant safety requirements and was tested according to:

TÜV PS PPP 52064 02.87
EN 60529 10.91

DIN EN 60439-1 04.94
subcl. 7.2 and 8.2.7

Report No.: 03310046882, E – (B 96 07 12010 102)

Released with the above certificate number by the
certification body of TÜV PRODUCT SERVICE GMBH.

Department: FFMMCH1 / he
Date: 03-18-1999

