



Product Service

# CERTIFICATE

No. Z2 12 06 12010 013

**Holder of Certificate:** Rittal GmbH & Co. KGAuf dem Stützelberg  
35745 Herborn  
GERMANY**Production Facility(ies):**

79671

**Certification Mark:****Product:**

Switchgear Cabinets

**Model(s):**type tested cabinets, empty enclosures  
Series KS**Parameters:**

degree of protection:	IP 66 one door version without viewing window
degree of protection:	IP 56 one door version with viewing window two door version
material:	enclosure GFK viewing window plexiglass
wall thickness:	enclosure 2,5 - 3,0 mm door 2,5 - 3,0 mm viewing window 2,5 - 3,0 mm
dimensions:	200 x 300 x 150 mm to 1000 x 1000 x 300 mm

**Tested according to:** DIN EN 62208:2005

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition the certification holder must not transfer the certificate to third parties. See also notes overleaf.

**Test report no.:** 713006268**Date,** 2012-06-27

( Horst Kristen )

Page 1 of 1

