

CERTIFICATE

issued by

Rittal GmbH & Co. KG

Auf dem Stützelberg
D-35745 Herborn

Quality Management

Herewith we confirm that the Rittal KL enclosure

1514.510	1528.510	1516.510	1515.510	1517.510
1518.510	1519.510	1500.510	1529.510	1502.510
1501.510	1503.510	1507.510	1589.510	1504.510
1508.510	1511.510	1505.510	1509.510	1506.510
1510.510	1512.510	1527.510	1513.510	-

complies with the requirements of the hosedown test according to UL50 Type 4 (NEMA 4) and fulfil the protection category IP66 according to EN 60529 "Degrees of protection provided by enclosures" dated September 2000.

Herborn, 2014-02-03


Axel Remmert
Quality Management Laboratory



Rittal's test laboratory is accredited with the German Accreditation Council (DAkKS) No. D-PL-17086-01-01 and Underwriters Laboratories Inc.

Rittal GmbH & Co. KG
Personally liable:
Rittal Management GmbH,
Schwende

Management:
Friedhelm Loh (President)
Karl Christoph Caselitz
Dr. Guido Stannek
Dr. Thomas Steffen
Hermann Tetzner
Michael Weiher

Rittal GmbH & Co. KG
Auf dem Stützelberg
D-35745 Herborn
Phone: +49(0)27 72 5 05-0
Fax: +49(0)27 72 5 05-23 19
E-Mail: info@rittal.de
www.rittal.de
HRA 6126 Wetzlar

ENCLOSURES

POWER DISTRIBUTION

CLIMATE CONTROL

IT INFRASTRUCTURE

SOFTWARE & SERVICES

