

CERTIFICATE

issued by

Rittal GmbH & Co. KG

Auf dem Stützelberg
D-35745 Herborn

Quality Management

Herewith we confirm that the Rittal KL enclosure

| | | | | |
|----------|----------|----------|----------|----------|
| 1530.510 | 1531.510 | 1535.510 | 1532.510 | 1536.510 |
| 1539.510 | 1533.510 | 1537.510 | 1534.510 | 1538.510 |
| 1540.510 | 1542.510 | 1541.510 | - | - |

complies with the requirements of the atomized water test according to UL50 Type 12 (NEMA 12) and fulfil the protection category IP55 according to EN 60529 "Degrees of protection provided by enclosures" dated September 2000.

Herborn, 2014-02-03


Axel Remmert
Quality Management Laboratory



Rittal's test laboratory is accredited with the German Accreditation Council (DAkKS) No. D-PL-17086-01-01 and Underwriters Laboratories Inc.

Rittal GmbH & Co. KG
Personally liable:
Rittal Management GmbH,
Schwende

Management:
Friedhelm Loh (President)
Karl Christoph Caselitz
Dr. Guido Stannek
Dr. Thomas Steffen
Hermann Tetzner
Michael Weiher

Rittal GmbH & Co. KG
Auf dem Stützelberg
D-35745 Herborn
Phone: +49(0)27 72 5 05-0
Fax: +49(0)27 72 5 05-23 19
E-Mail: info@rittal.de
www.rittal.de
HRA 6126 Wetzlar

ENCLOSURES

POWER DISTRIBUTION

CLIMATE CONTROL

IT INFRASTRUCTURE

SOFTWARE & SERVICES



FRIEDHELM LOH GROUP