



Certificate of Compliance

Certificate: 312M

Master Contract: 75597 (165083)

Project: 70180877

Date Issued: May 2, 2018

Issued to: Rittal GmbH & Co. KG
Auf dem Stützelberg
Herborn, 35745
GERMANY

The products listed below are eligible to bear the CSA Mark shown



Issued by: *Lizon Deschamps*
Lizon Deschamps

PRODUCTS

CLASS 3211 03 - INDUSTRIAL CONTROL EQUIPMENT - Motor Controllers - Auxiliary Devices

CLASS 3211 23 - INDUSTRIAL CONTROL EQUIPMENT - Motor Controllers - Auxiliary Devices

- Limit switches, in non-metallic enclosure, with one NO and one NC contact, Type SZ2586 code rated A300, Q300.

Note: Limit switches with general purpose enclosure with conduit entries other than NPT are accepted as "Special Component Devices" for use where the combination is acceptable to the Canadian Standards Association.

- Limit switches, open type, Types 2586.010, 4127.010, 4127.210 and 4315.720, in non-metallic enclosure, with one NO and one NC contact.

Note: The open type switches are certified for use in equipment where the acceptability of the combination is to be determined by CSA International.

- Limit Switches in non-metallic enclosure, Enclosure Types 3 indoor, 4 indoor and 12, Types 4127.000, 2586.000, 4127.200, 4127.009, 4127.009, 2 pole, code rated A600 and Q600 or resistive loads of 40V dc, 6A max.



Certificate: 312M

Master Contract: 75597 (165083)

Project: 70180877

Date Issued: May 2, 2018

- Limit switches, open type, Type 325055, 4315.350, 4315.550, SZ 2500.470, rated A300, B300, Q300, 230 Vac/6A (general use).

Notes:

1. The type designations may be completed with suffixes indicating contact design and mechanism, and mechanical details.
2. Limit switches with general purpose enclosure with conduit entries other than NPT are accepted as "special component devices" for use where the combination is acceptable to CSA International.
3. The switches have been accepted as end of the line devices, where one conduit entry is used only.
4. The switches are certified for use in equipment where the acceptability of the combination is to be determined by CSA.

APPLICABLE REQUIREMENTS

CAN/CSA-C22.2 No. 0-10	-	General Requirements - Canadian Electrical Code, Part II
CSA-C22.2 No. 14-13	-	Industrial Control Equipment
CAN/CSA-C22.2 No 60947-1-13	-	Low-Voltage Switchgear and Controlgear - Part 1: General rules
CAN/CSA-C22.2 No 60947-5-1-14	-	Low-voltage switchgear and controlgear - Part 5-1: Control circuit devices and switching elements - Electromechanical control circuit devices

MARKINGS

The manufacturer is required to apply the following markings:

- Products shall be marked with the markings specified by the particular product standard.
- Products certified for Canada shall have all Caution and Warning markings in both English and French.

Additional bilingual markings not covered by the product standard(s) may be required by the Authorities Having Jurisdiction. It is the responsibility of the manufacturer to provide and apply these additional markings, where applicable, in accordance with the requirements of those authorities.

The products listed are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US (indicating that products have been manufactured to the requirements of both Canadian and U.S. Standards) or with adjacent indicator 'US' for US only or without either indicator for Canada only.

Company's name, and/or CSA file number 75597 (165083), type designation, electrical ratings, serial number or date coding, the CSA Mark appear in a permanent manner on each unit, and any other information as specified in the Certification Report.