

CERTIFICATE

issued by

Rittal GmbH & Co. KG

Auf dem Stützelberg
D-35745 Herborn

Quality Management

We confirm that the following Rittal SE single enclosures comply with the protection category IP66 according to EN 60529 „Degrees of protection provided by enclosures“ dated September 2014 and the requirements of the hosedown test according to UL 50E Type 3R and Type 4 (NEMA 3R & 4):

5830580

5831580

5834580

Herborn, 2018-03-27


Axel Remmert
Quality Management Laboratory



Rittal's test laboratory is accredited with the German Accreditation Council (DAkkS) No. D-PL-17086-01-00 and Underwriters Laboratories Inc.

Rittal GmbH & Co. KG
Personally liable:
Rittal Management GmbH,
Schwende

Management:
Dr.-Ing. Karl-Ulrich Köhler (CEO)
Hans Sondermann
Dr. Thomas Steffen
Andreas Huck
Carsten Röttchen

Rittal GmbH & Co. KG
Auf dem Stützelberg
D-35745 Herborn
Phone: +49(0)27 72 5 05-0
Fax: +49(0)27 72 5 05-23 19
E-Mail: info@rittal.de
www.rittal.de
HRA 6126 Wetzlar

ENCLOSURES

POWER DISTRIBUTION

CLIMATE CONTROL

IT INFRASTRUCTURE

SOFTWARE & SERVICES

