

# CERTIFICATE

issued by

**Rittal GmbH & Co. KG**

Auf dem Stützelberg  
D-35745 Herborn

Quality Management

Confirmation of fulfilment of protection category IK08 according to EN 50102 (IEC 62262) „Degrees of protection provided by enclosures for electrical equipment against external mechanical impacts (IK code)” dated September 1997 for the following material numbers:

material no.	for width	for height
VX 8618.000	= 600 mm	= 1800 mm
VX 8618.010	= 800 mm	= 1800 mm
VX 8618.020	= 600 mm	= 2000 mm
VX 8618.030	= 800 mm	= 2000 mm
VX 8618.040	= 600 mm	= 2200 mm
VX 8618.050	= 800 mm	= 2200 mm



Herborn, 2018-11-02

Axel R Emmert  
Quality Management Laboratory



Rittal's test laboratory is accredited with the German Accreditation Council (DAkkS) No. D-PL-17086-01-00 and Underwriters Laboratories Inc.

Rittal GmbH & Co. KG  
Personally liable:  
Rittal Management GmbH,  
Schwende

Management:  
Dr.-Ing. Karl-Ulrich Köhler (CEO)  
Hans Sondermann  
Dr. Thomas Steffen  
Andreas Huck  
Carsten Röttchen

Rittal GmbH & Co. KG  
Auf dem Stützelberg  
D-35745 Herborn  
Phone: +49(0)27 72 5 05-0  
Fax: +49(0)27 72 5 05-23 19  
E-Mail: info@rittal.de  
www.rittal.de  
HRA 6126 Wetzlar

ENCLOSURES

POWER DISTRIBUTION

CLIMATE CONTROL

IT INFRASTRUCTURE

SOFTWARE & SERVICES

