

CERTIFICATE OF COMPLIANCE

Certificate Number 20181029-SA33245
Report Reference SA33245-20181025
Issue Date 2018-October-29

Issued to: RITTAL GmbH & Co. KG
Auf dem Stuetzelberg
35745 Herborn GERMANY

**This is to certify that
representative samples of**

COMMERCIAL PROCESSING LIQUID COOLERS
See next page for models

Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.

Standard(s) for Safety:

UL 60335-1 Safety of Household and Similar Electrical
Appliances, Part 1: General Requirements,
CSA C22.2 No. 60335-1-11 Household and similar
electrical appliances — Safety —Part 1: General
requirements,
UL 60335-2-40 Household and Similar Electrical
Appliances, Part 2: Particular Requirements for Electrical
Heat Pumps, Air-Conditioners and Dehumidifiers,
CSA C22.2 No. 60335-2-40-12 SAFETY OF HOUSEHOLD
AND SIMILAR ELECTRICAL APPLIANCES - PART 2-40:
PARTICULAR REQUIREMENTS FOR ELECTRICAL HEAT
PUMPS, AIR-CONDITIONERS AND DEHUMIDIFIERS

Additional Information:

See the UL Online Certifications Directory at
www.ul.com/database for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's
Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please
contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



CERTIFICATE OF COMPLIANCE

Certificate Number 20181029-SA33245
Report Reference SA33245-20181025
Issue Date 2018-October-29

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Water Chiller

SK3320200

380-415V, 2.17 A, 3ph, 50Hz, 2500 W
440-480V, 1.95 A, 3ph, 60Hz, 2400 W
R134a, 460g (16.22z); HP: 25 bar; LP: 16 bar;
-5 to +50°C Ambient Operating Temperature Range;
+5 to +35°C Cooling Medium Operating Temperature Range;
Fluid Flow Rate 7 l/min
Max Fluid Pressure 2.5 bar@ 50 Hz, 3.6 bar@ 60 Hz

SK3334400

380-415V, 3.97 A, 3ph, 50Hz, 5500 W
440-480V, 3.47 A, 3ph, 60Hz, 5400 W
R134a, 930g (32.80z); HP: 25 bar; LP: 16 bar;
-5 to +50°C Ambient Operating Temperature Range;
+5 to +35°C Cooling Medium Operating Temperature Range;
Fluid Flow Rate 15 l/min
Max Fluid Pressure 3.3 bar@ 50 Hz, 4.9 bar@ 60 Hz



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

