

CERTIFICATE

issued by

Rittal GmbH & Co. KG

Auf dem Stützelberg
D-35745 Herborn

Quality Management

We hereby confirm that the Rittal CS New Basic enclosure 9783.530, 9783.610 and 9784.540 comply with the requirements of UL 50E Type 3R (Nema3R) and fulfil the protection category IP 55 according to EN 60529 "Degrees of protection provided by enclosures" dated September/2014.

Herborn, 2018-12-03


Axel Remmert
Quality Management Laboratory



Rittal's test laboratory is accredited with the German Accreditation Council (DAkKS) No. D-PL-17086-01-00 and Underwriters Laboratories Inc.

Rittal GmbH & Co. KG
Personally liable:
Rittal Management GmbH,
Schwende

Management:
Dr.-Ing. Karl-Ulrich Köhler (CEO)
Hans Sondermann
Andreas Huck
Dr. Thomas Steffen
Carsten Röttchen

Rittal GmbH & Co. KG
Auf dem Stützelberg
D-35745 Herborn
Phone: +49(0)27 72 5 05-0
Fax: +49(0)27 72 5 05-23 19
E-Mail: info@rittal.de
www.rittal.de
HRA 6126 Wetzlar

ENCLOSURES

POWER DISTRIBUTION

CLIMATE CONTROL

IT INFRASTRUCTURE

SOFTWARE & SERVICES

