

# CERTIFICATE

issued by

**Rittal GmbH & Co. KG**

Auf dem Stützelberg  
D-35745 Herborn

Quality Management

**Confirmation of protection class of hygenic design enclosures:**

**Material numbers:**

HD 1670.600	HD 1671.600	HD 1672.600	HD 1674.600	HD 1675.600
HD 1676.600	HD 1302.600	HD 1306.600	HD 1307.600	HD 1308.600
HD 1310.600	HD 1314.600	HD 1315.600	HD 1316.600	HD 1317.600
HD 1320.600	HD 4000.285	HD 4000.485	HD 4000.685	HD 4000.885

Above material number complies with the following protection category:

1. IP66 acc. to DIN EN 60529 "Degrees of protection provided by enclosures" dtd. September 2014
2. IP X9 acc. to DIN EN 60529 "Degrees of protection provided by enclosures" dtd. September 2014



**Herborn, 03-08-2019**

**Fabian Werner**

Quality Engineer Test Laboratory



Rittal's test laboratory is accredited with the German Accreditation Council (DAKkS) No. D-PL-17086-01-00 and Underwriters Laboratories Inc.

Rittal GmbH & Co. KG  
Persönlich haftend:  
Rittal Management GmbH,  
Schwende

Management:  
Dr.-Ing. Karl-Ulrich Köhler (CEO)  
Hans Sondermann  
Dr. Thomas Steffen  
Andreas Huck  
Carsten Röttchen

Rittal GmbH & Co. KG  
Auf dem Stützelberg  
D-35745 Herborn  
Phone: +49(0)27 72 5 05-0  
Fax: +49(0)27 72 5 05-23 19  
E-Mail: info@rittal.de  
www.rittal.de  
HRA 6126 Wetzlar

ENCLOSURES

POWER DISTRIBUTION

CLIMATE CONTROL

IT INFRASTRUCTURE

SOFTWARE & SERVICES

