



中国国家强制性产品认证证书

证书编号：2017010305949329

委托人名称、地址

Rittal GmbH & Co. KG

Auf dem Stützelberg, D-35745 Herborn, Germany

生产者（制造商）名称、地址

Siemens AG

Werner-von-Siemens-Strasse 48, D-92220 Amberg, Germany

生产企业名称、地址

Siemens AG

Werner-von-Siemens Strasse 48, D-92220 Amberg, Germany

产品名称和系列、规格、型号

位置开关

SZ 2586.010, SZ 4127.010, SZ 4315.520, SZ 4315.320, SZ 4315.530, SZ 4315.330, SZ 2586.901, SZ 325055, SZ 4127.210, SZ 4315.350, SZ 4315.550, SZ 2500.460, SZ 2500.470, SZ 4315.710, SZ 4315.720; 参数详见附件

产品标准和技术要求

GB/T14048.5-2017

上述产品符合强制性产品认证实施规则 CNCA-C03-02:2014 的要求，特发此证。

发证日期：2019 年 04 月 03 日 有效期至：2022 年 03 月 23 日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书为变更证书，证书首次颁发日期：2017 年 03 月 23 日

本证书的相关信息可通过国家认监委网站 www.cnca.gov.cn 查询



主任：

陆楠



中国质量认证中心



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

CERTIFICATE NO.: 2017010305949329

NAME AND ADDRESS OF THE APPLICANT

Rittal GmbH & Co. KG
Auf dem Stützelberg, D-35745 Herborn, Germany

NAME AND ADDRESS OF THE MANUFACTURER

Siemens AG
Werner-von-Siemens-Strasse 48, D-92220 Amberg, Germany

NAME AND ADDRESS OF THE FACTORY

Siemens AG
Werner-von-Siemens Strasse 48, D-92220 Amberg, Germany

PRODUCT NAME, MODEL AND SPECIFICATION

Standard Position switch
SZ 2586.010, SZ 4127.010, SZ 4315.520, SZ 4315.320, SZ 4315.530, SZ 4315.330, SZ 2586.901, SZ 325055, SZ 4127.210, SZ 4315.350, SZ 4315.550, SZ 2500.460, SZ 2500.470, SZ 4315.710, SZ 4315.720; See the Appendix

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T14048.5-2017

This is to certify that the above mentioned product(s) complies with the requirements of implementation rules for compulsory certification(REFNO.CNCA-C03-02:2014).

Valid from: Apr.03,2019

Valid until: Mar.23,2022

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

Date of original issued: Mar.23,2017

The certificate information is available through CNCA's website: www.cnca.gov.cn



President:

Lu Mei



CHINA QUALITY CERTIFICATION CENTRE



中国国家强制性产品认证证书

附 录

第 1 页 共 1 页

证书编号：2017010305949329

纸 号：2277410

SZ 2586.010,SZ 4127.010,SZ 4315.520,SZ 4315.320,SZ 4315.530,SZ 4315.330,
SZ 2586.901,SZ 325055,SZ 4127.210,SZ 4315.350,SZ 4315.550,SZ 2500.460,
SZ 2500.470,SZ 4315.710,SZ 4315.720;

Ui:400V,250V (For types SZ 2500.460,SZ 2500.470 and SZ 4315.320);

Uimp:6kV,4kV(For types SZ 2500.460,SZ 2500.470 and SZ 4315.320);

Ith:10A,2.5A(For types SZ 2500.460 and SZ 2500.470), 6A(For types SZ 4315.320);

AC-15:Ue:AC230V/Ie:6A,Ue:AC240V/Ie:6A;

DC-13:Ue:DC24V/Ie:6A;

For types SZ 4315.320 only:

AC-15:Ue:AC230V/Ie:6A,Ue:AC240V/Ie:6A;

DC-13:Ue:DC24V/Ie:3A;

For types SZ 4315.710,SZ 4315.720,SZ 2500.460 and SZ 2500.470 only:

AC-15:Ue:AC230V/Ie:2.5A,Ue:AC240V/Ie:2.5A;

DC-13:Ue:DC24V/Ie:2.5A;

IP40,IP20(For types SZ 2500.460,SZ 2500.470 and SZ 4315.320 only).

注：此附录与证书同时使用时有效。



主 任：

陆 楠



中国质量认证中心