

CERTIFICATE

Rittal quality management

We confirm that the Rittal enclosure CM 5122.500 fulfills
the protection category IP 55 according to EN 60529 "Degrees of protection
provided by enclosures" dated September 2014 and meets the requirements
according to UL50 Type 12 (NEMA 12)
provided that appropriate base plates or end plates were selected.



Christian Haim
Quality Management Laboratory

16.03.2021