

CERTIFICATE

Permission to use the test mark

***VOLUNTARY PRODUCT TEST
BASED ON DIN EN 14511-1 - 4:2019***

– Performance tested –

TÜV NORD Systems GmbH & Co. KG, Hamburg (Germany),

hereby confirms that the applied P_c and EER of
the Liquid Chilled Packages series

“Blue e +”

of

RITTAL GmbH & Co. KG (Germany),

are in compliance with the defined tolerances
set by TÜV NORD Systems (5 %)

It is permitted that the Rittal Blue e+ series is marked with the following test mark:

TÜV NORD Systems GmbH & Co. KG
Test Laboratory for Ventilation, Air Conditioning, Refrigeration



Dipl.-Ing. Monika Steimle

Essen, 26 May 2020

The validity of the certificate is one year.
All regulations concerning test mark use are laid down in the corresponding agreement.

