

CERTIFICATE

issued by

Rittal GmbH & Co. KG

Auf dem Stützelberg
D-35745 Herborn

Quality Management

Confirmation of protection class of hygienic design enclosures:

Material numbers:

HD 4000.525	HD 4000.585	HD 4000.565	HD 4000.545	HD 4000.785
HD 4000.185	HD 4000.285	HD 4000.485	HD 4000.685	HD 4000.885
HD 4000.505				

Above material number complies with the following protection category:

1. IP66 acc. to DIN EN 60529 "Degrees of protection provided by enclosures" dtd. September 2014
2. IP X9 acc. to DIN EN 60529 "Degrees of protection provided by enclosures" dtd. September 2014
3. Nema 4X acc. to UL 50E "Standard for safety" dtd. October 2015

Herborn, 03-08-2019



Fabian Werner

Quality Engineer Test Laboratory

Rittal's test laboratory is accredited with the German Accreditation Council (DAkkS) No. D-PL-17086-01-00 and Underwriters Laboratories Inc.

Rittal GmbH & Co. KG
Persönlich haftend:
Rittal Management GmbH,
Schwende

Management:
Dr.-Ing. Karl-Ulrich Köhler (CEO)
Hans Sondermann
Dr. Thomas Steffen
Andreas Huck
Carsten Röttchen

Rittal GmbH & Co. KG
Auf dem Stützelberg
D-35745 Herborn
Phone: +49(0)27 72 5 05-0
Fax: +49(0)27 72 5 05-23 19
E-Mail: info@rittal.de
www.rittal.de
HRA 6126 Wetzlar

ENCLOSURES

POWER DISTRIBUTION

CLIMATE CONTROL

IT INFRASTRUCTURE

SOFTWARE & SERVICES

