

# CERTIFICATE

## Rittal quality management

We hereby confirm that the AX compact enclosure plastic

AX 1432.000 250x350x150 [mm]

AX 1434.000 300x400x200 [mm]

AX 1444.000 400x400x200 [mm]

were subjected to a pressure wave simulation and a dynamic pressure test with regard to aerodynamic effects to prove their strength in accordance with Ril 853.2001 A01. An impairment of the functionality or externally visible damage after the test could not be determined.



16.03.2021

Axel Remmert  
Quality Management Laboratory