




Ref. Certif. No.

DE 7 -0494

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

## CB TEST CERTIFICATE

Product	Chiller
Name and address of the applicant	Rittal GmbH & Co.KG Auf dem Stützelberg, 35745 Herborn Germany
Name and address of the manufacturer	Rittal GmbH & Co.KG Auf dem Stützelberg, 35745 Herborn Germany
Name and address of the factory	Kelvin s.r.l Via Degli Imprenditore 15, 37067 Valeggio Sul Minco (VR) Italy
Note: When more than one factory, please report on page 2	<input type="checkbox"/> Additional information on page 2
Ratings and principal characteristics	380 - 415 V, 3~, 50 Hz, 2490 W; 440 - 480 V, 3~, 60 Hz, 2720 W, R-134a, 760 g, HP: 25 bar, LP: 16 bar, IP24
Trademark (if any)	
Customer's Testing Facility (CTF) Stage used	CTF stage 3
Model / Type Ref.	SK 3334300
Additional information (if necessary may also be reported on page 2)	<input type="checkbox"/> Additional information on page 2
A sample of the product was tested and found in conformity with IEC	IEC 60335-1: 2010, 60335-2-40: 2013
As shown in the Test Report Ref. No. which forms part of Certificate	35210775

This CB Test Certificate is issued by the National Certification Body:



**TUV NORD**  
Certification

Date: 18.01.2019

Signature:

Michael Eck

Certification Department