

CERTIFICATE

Rittal quality management

Herewith we confirm that the design of the Rittal glazed door
for enclosure system VX25, article no.:

8618.000	8618.010	8618.020
8618.030	8618.040	8618.050

fulfil the protection category IP55 according to EN 60529:1991/A2:2013/AC:2019-02
"Degrees of protection provided by enclosures".

The test was carried out and documented in a test report.



2021-02-22

Axel Remmert
Quality Management Laboratory