## **UK Declaration of Conformity**

Dri2116797en

We,

Rittal Limited, Braithwell Way, Hellaby Rotherham, S66 8QY, UK

declare that the products

## System enclosures SE 8 IP 66/NEMA 4

SE 5830.580 SE 5831.580 SE 5834.580

are conform to the following Statutory Instruments:

**Electrical Equipment (Safety) Regulations 2016** 

Applied designated standards:

## EN 62208

Empty enclosures for low-voltage switchgear and controlgear assemblies - General requirements (corrosion resistance in accordance with section 9.13.2.1)

In case of any amendments to the assembly not explicitly agreed with us, this UK Declaration of Conformity shall be invalidated.

Rotherham,

Responsible for documentation: Rittal Limited, Braithwell Way, Hellaby Rotherham, S66 8QY, UK

02/12/2021

Shane Hope, Managing Director, Rittal Limited



SCHALTSCHRÄNKE

STROMVERTEILUNG

KLIMATISIERUNG

FRIEDHELM LOH GROUP