

产品认证证书

II型自愿认证

证书编号: CQC2017010305949329

发证日期: 2021年12月26日

有效期至: 2030年06月18日

委托人名称 及注册地址	Rittal GmbH & Co. KG Auf dem Stützelberg, D-35745 Herborn, 德国
制造商名称 及注册地址	Rittal GmbH & Co. KG Auf dem Stützelberg, D-35745 Herborn, 德国
生产企业名称 及生产地址	Siemens AG Werner-von-Siemens Strasse 48, D-92220 Amberg, Germany
产品名称和系列、 规格、型号	位置开关 SZ 2586.010,SZ 4127.010,SZ 4315.520,SZ 4315.320,SZ 4315.530,SZ 4315.330,SZ 2586.901,SZ 325055,SZ 4127.210,SZ 4315.350,SZ 4315.550,SZ 2500.460,SZ 2500.470,SZ 4315.710,SZ 4315.720; 参数详见附件
产品标准和技术要求	GB/T 14048.5-2017
认证模式	产品型式试验+初次工厂检查+获证后监督

上述产品符合 CQC12-000001-2020 认证规则的要求, 特发此证。

本证书为变更证书, 证书首次颁发日期: 2020年08月13日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

可通过扫描下方二维码或登录国家认监委网站 (www.cnca.gov.cn) 查验证书信息



授权签字人

陈昕

签发

谢肇煦



中国质量认证中心



<http://www.cqc.com.cn>

中国·北京·南四环西路188号9区 100070

电话: +86 10 83886666

C(2) 0116558

CERTIFICATE OF PRODUCT CERTIFICATION

TYPE II CQC CERTIFICATION

CERTIFICATE NO.: CQC2017010305949329

Valid from: Dec.26,2021

Valid until: Jun.18,2030

NAME AND REGISTERED ADDRESS OF THE APPLICANT Rittal GmbH & Co. KG
Auf dem Stützelberg, D-35745 Herborn, Germany

NAME AND REGISTERED ADDRESS OF THE MANUFACTURER Rittal GmbH & Co. KG
Auf dem Stützelberg, D-35745 Herborn, Germany

NAME AND LOCATION OF THE FACTORY Siemens AG
Werner-von-Siemens Strasse 48, D-92220 Amberg, Germany

PRODUCT NAME, MODEL AND SPECIFICATION Standard Position switch
SZ 2586.010,SZ 4127.010,SZ 4315.520,SZ 4315.320,SZ 4315.530,SZ 4315.330,SZ 2586.901,SZ 325055,SZ 4127.210,SZ 4315.350,SZ 4315.550,SZ 2500.460,SZ 2500.470,SZ 4315.710,SZ 4315.720; See the Appendix

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS GB/T 14048.5-2017

TYPE OF CERTIFICATION SCHEMES Type Testing of Product + Initial Factory Inspection + Follow up Factory Inspection

This is to certify that the above mentioned product(s) complies with the requirements of certification rules of CQC12-000001-2020.

Date of original issued: Aug.13,2020

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

The certificate information is available through the QR code below or CNCA's website: www.cnca.gov.cn



SIGN BY

陈昕

SIGNATURE

谢肇煦



CHINA QUALITY CERTIFICATION CENTRE



产品认证证书

II型自愿认证

附 录

证书编号: CQC2017010305949329

第 1 页 共 1 页

纸 号: 116558

SZ 2586.010,SZ 4127.010,SZ 4315.520,SZ 4315.320,SZ 4315.530,SZ 4315.330,

SZ 2586.901,SZ 325055,SZ 4127.210,SZ 4315.350,SZ 4315.550,SZ 2500.460,

SZ 2500.470,SZ 4315.710,SZ 4315.720;

Ui:400V,250V (For types SZ 2500.460,SZ 2500.470 and SZ 4315.320);

Uimp:6kV,4kV(For types SZ 2500.460,SZ 2500.470 and SZ 4315.320);

Ith:10A,2.5A(For types SZ 2500.460 and SZ 2500.470), 6A(For types SZ 4315.320);

AC-15:Ue:AC230V/Ie:6A,Ue:AC240V/Ie:6A;

DC-13:Ue:DC24V/Ie:6A;

For types SZ 4315.320 only:

AC-15:Ue:AC230V/Ie:6A,Ue:AC240V/Ie:6A;

DC-13:Ue:DC24V/Ie:3A;

For types SZ 4315.710,SZ 4315.720,SZ 2500.460 and SZ 2500.470 only:

AC-15:Ue:AC230V/Ie:2.5A,Ue:AC240V/Ie:2.5A;

DC-13:Ue:DC24V/Ie:2.5A;

IP40,IP20(For types SZ 2500.460,SZ 2500.470 and SZ 4315.320 only).

注: 此附录与证书同时使用时有效。



中国质量认证中心

