




CERTIFICATE

issued by

Rittal GmbH & Co. KG

Auf dem Stützelberg
D-35745 Herborn

Quality Management



Herewith we confirm that the Rittal stainless steel enclosures AE 1018.600 comply with the requirements according to UL 50 Type 12 (NEMA 12) and fulfil the protection category IP 55 according to EN 60529 „Degrees of protection provided by enclosures“ dated September 2000.

Herborn, 11.09.2008



Helmut Appl
Quality Management Laboratory



Rittal's test laboratory is accredited with the German Accreditation Council (DAR) and Underwriters Laboratories Inc.

Rittal GmbH & Co. KG
Personally liable:
Rittal Management GmbH,
Schwende

Management
Norbert Müller (President)
Bernd Eckel,
Friedemann Hensgen,
Peter Krawat, Willi Schmid,
Dr. Thomas Steffen,
Michael Weiher
HRA 6126 Wetzlar

Rittal GmbH & Co. KG
Auf dem Stützelberg
D-35745 Herborn
Phone: +49(0)27 72 5 05-0
Fax: +49(0)27 72 5 05-23 19
E-Mail: info@rittal.de
www.rittal.de

