



# CERTIFICATE


---

issued by

**Rittal GmbH & Co. KG**

Auf dem Stützelberg  
D-35745 Herborn

Quality Management



**Herewith we confirm that the Rittal stainless steel enclosures AE 1007.600 comply with the requirements of the Hosedown test according to UL 50 Type 4X (NEMA 4X) and fulfil the protection category IP 66 according to EN 60529 „Degrees of protection provided by enclosures“ dated September 2000.**

Herborn, 07.08.2008



---

Helmut Appl  
Quality Management Laboratory



Rittal's test laboratory is accredited with the German Accreditation Council (DAR) and Underwriters Laboratories Inc.

---

Rittal GmbH & Co. KG  
Personally liable:  
Rittal Management GmbH,  
Schwende

Management  
Norbert Müller (President)  
Bernd Eckel,  
Friedemann Hensgen,  
Peter Krawat, Willi Schmid,  
Dr. Thomas Steffen,  
Michael Weiher  
HRA 6126 Wetzlar

Rittal GmbH & Co. KG  
Auf dem Stützelberg  
D-35745 Herborn  
Phone: +49(0)27 72 5 05-0  
Fax: +49(0)27 72 5 05-23 19  
E-Mail: [info@rittal.de](mailto:info@rittal.de)  
[www.rittal.de](http://www.rittal.de)

