



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

本翻译文件不具有法律效力，
不得单独使用
This translated document
does not have legal validity and
cannot be used in isolation

CERTIFICATE NO.: 2024010302713514

NAME AND ADDRESS OF THE APPLICANT

Rittal GmbH & Co. KG
Auf dem Stützelberg, D-35745 Herborn, Germany

NAME AND ADDRESS OF THE MANUFACTURER

Rittal GmbH & Co. KG
Auf dem Stützelberg, D-35745 Herborn, Germany

NAME AND LOCATION OF THE FACTORY

Woehner GmbH & Co. KG
Moenchroedener Str. 10, 96472 Roedental, Germany

PRODUCT NAME,MODEL AND SPECIFICATION

Fuse-switch-disconnector

SV 9677.100, SV 9677.110 , SV 9677.200, SV 9677.210; Uimp:12kV; Ui:1000V; Ith: 250A(SV 9677.100), 250A(SV 9677.110),400A(SV 9677.200), 400A(SV 9677.210); Ue:400V(AC-23B), 690V(AC-21B,AC-22B); Ie: 250A(SV 9677.100), 250A(SV 9677.110),400A(SV 9677.200), 400A(SV 9677.210); Iq:100kA(690V),120kA(400V) ; Utilization Category : AC-21B,AC-22B,AC-23B; Poles : 3P; 50/60Hz

STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T 14048.3-2017

This is to certify that the above mentioned product(s) complies with the requirements of implementation rules for compulsory certification(REFNO. CNCA-C03-02:2024).

Valid from: Oct.28,2024

Valid until: Sep.13,2029

The certificate information and validity could be checked by scanning the QR code below or logging in to the website of the issuing authority, or on the website of the CNCA (www.cnca.gov.cn).



SIGNATURE:

谢肇煦



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

CHINA QUALITY CERTIFICATION CENTRE CO., LTD.

