

# CERTIFICATE

issued by

**Rittal GmbH & Co. KG**

Auf dem Stützelberg  
D-35745 Herborn

Quality Management

Herewith we confirm that the Rittal enclosures TS 8684.500 comply with the requirements according to UL 50 Type 12 (NEMA 12) and fulfil the protection category IP 55 according to EN 60529 "Degrees of protection provided by enclosures" dated September 2000.

Herborn, 2012-06-06

  
Axel Remmert  
Quality Management Laboratory



Rittal's test laboratory is accredited with the German Accreditation Council (DAR) No. DAP-PL-3025.00 and Underwriters Laboratories Inc.

Rittal GmbH & Co. KG  
Personally liable:  
Rittal Management GmbH,  
Schwende

Geschäftsführung:  
Friedhelm Loh (President)  
Karl Christoph Caselitz,  
Dr. Thomas Steffen  
Hermann Tetzner  
Michael Weiher

Rittal GmbH & Co. KG  
Auf dem Stützelberg  
D-35745 Herborn  
Phone: +49(0)27 72 5 05-0  
Fax: +49(0)27 72 5 05-23 19  
E-Mail: info@rittal.de  
www.rittal.de  
HRA 6126 Wetzlar

ENCLOSURES

POWER DISTRIBUTION

CLIMATE CONTROL

IT INFRASTRUCTURE

SOFTWARE & SERVICES

