

CERTIFICATE

issued by

Rittal GmbH & Co. KG

Auf dem Stützelberg
D-35745 Herborn

Quality Management

Hereby we confirm that the Rittal compact enclosures AE 1032.500 and AE 1035.500 complies with the requirements of UL 50 Type 12 (NEMA 12) and fulfil the protection category IP 55 according to EN 60529 „Degrees of protection provided by enclosures“ dated September 2000.



Herborn, 15.02.2012

Axel Remmert
Quality Management Laboratory



Rittal's test laboratory is accredited with the German Accreditation Council (DAR) No. DAP-PL-3025.00 and Underwriters Laboratories Inc.

Rittal GmbH & Co. KG
Personally liable:
Rittal Management GmbH,
Schwende

Geschäftsführung:
Friedhelm Loh (President)
Bernd Eckel,
Ralph Lindackers
Dr. Thomas Steffen
Michael Weiher

Rittal GmbH & Co. KG
Auf dem Stützelberg
D-35745 Herborn
Phone: +49(0)27 72 5 05-0
Fax: +49(0)27 72 5 05-23 19
E-Mail: info@rittal.de
www.rittal.de
HRA 6126 Wetzlar



SCHALTSCHRÄNKE

STROMVERTEILUNG

KLIMATISIERUNG

IT-INFRASTRUKTUR

SOFTWARE & SERVICE

FRIEDHELM LOH GROUP