



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

本翻译文件不具有法律效力，
不得单独使用
This translated document
does not have legal validity and
cannot be used in isolation

CERTIFICATE NO.: 2026010302852573

NAME AND ADDRESS OF THE APPLICANT

Rittal GmbH & Co. KG
Auf dem Stützelberg, D-35745 Herborn, Germany

NAME AND ADDRESS OF THE MANUFACTURER

Rittal GmbH & Co. KG
Auf dem Stützelberg, D-35745 Herborn, Germany

NAME AND LOCATION OF THE FACTORY

Aparator SA
Ostaszewo 57C, 87-148 Lysomice, Poland

PRODUCT NAME,MODEL AND SPECIFICATION

Fuse-Switch-Disconnecter

RX NH000-125A ;Uimp :6kV ;Ui :1000V ;Ith :125A ;Iq :AC100kA,DC20kA ;Ue :AC400V/AC500V/AC690V/DC250V ;
Ie : AC125A/125A/63A , DC100A ; Utilization Category : AC-23B/22B/21B, DC-22B ; 50/60Hz ; Levels of Protection :
IP30 (Working face) ; Poles : 3P

STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T 14048.3-2017

This is to certify that the above mentioned product(s) complies with the requirements of
implementation rules for compulsory certification(REFNO. CNCA-C03-02:2024).

Valid from: Mar.31,2026

Valid until: Mar.30,2031

The certificate information and validity could be checked by scanning the QR code below or logging in to
the website of the issuing authority, or on the website of the CNCA (www.cnca.gov.cn).



SIGNATURE:



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

CHINA QUALITY CERTIFICATION CENTRE CO., LTD.

