



# CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

本翻译文件不具有法律效力，  
不得单独使用  
This translated document  
does not have legal validity and  
cannot be used in isolation

**CERTIFICATE NO.:** 2026010302852575

**NAME AND ADDRESS OF THE APPLICANT**

Rittal GmbH & Co. KG  
Auf dem Stützelberg, D-35745 Herborn, Germany

**NAME AND ADDRESS OF THE MANUFACTURER**

Rittal GmbH & Co. KG  
Auf dem Stützelberg, D-35745 Herborn, Germany

**NAME AND LOCATION OF THE FACTORY**

Aparator SA  
Ostaszewo 57C, 87-148 Lysomice, Poland

**PRODUCT NAME,MODEL AND SPECIFICATION**

Fuse-Switch-Disconnecter

RX NH3-630A ; Uimp : 12kV ; Ui : 1000V ; Ith : 630A(Screw wiring)、500A(Frame-type wiring and prism-type wiring) ;  
Iq :AC100/120/120kA, DC25kA ;Icw :15kA/1s ;Ue :AC400V/500V/690V, DC440V ;Ie :AC630A/630A/630A, DC630A ;  
Utilization Category : AC-23B/22B/21B, DC-22B ; 50/60Hz ; Levels of Protection : IP30 ( Working face ) ; Poles : 3P

**STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS**

GB/T 14048.3-2017

This is to certify that the above mentioned product(s) complies with the requirements of implementation rules for compulsory certification(REFNO. CNCA-C03-02:2024).

**Valid from:** Mar.31,2026

**Valid until:** Mar.30,2031

The certificate information and validity could be checked by scanning the QR code below or logging in to the website of the issuing authority, or on the website of the CNCA (www.cnca.gov.cn).



SIGNATURE:



中国质量认证中心  
CHINA QUALITY CERTIFICATION CENTRE

CHINA QUALITY CERTIFICATION CENTRE CO., LTD.

