

CERTIFICATE

issued by

Rittal GmbH & Co. KG

Auf dem Stützelberg
D-35745 Herborn

Quality Management

Hereby we confirm that the Rittal standard enclosure SE 8 fulfil the protection category IK 10 according to EN 50102 (IEC 62262) „Degrees of protection provided by enclosures for electrical equipment against external mechanical impacts (IK code)“ dated September 1997.

Herborn, 2014-12-03


Axel Remmert
Quality Management Laboratory



Rittal's test laboratory is accredited with the German Accreditation Council (DAkKS) No. D-PL-17086-01-01 and Underwriters Laboratories Inc.

Rittal GmbH & Co. KG
Personally liable:
Rittal Management GmbH,
Schwende

Management:
Friedhelm Loh (President)
Karl Christoph Caselitz
Dr. Guido Stannek
Dr. Thomas Steffen
Hermann Tetzner
Michael Weiher

Rittal GmbH & Co. KG
Auf dem Stützelberg
D-35745 Herborn
Phone: +49(0)27 72 5 05-0
Fax: +49(0)27 72 5 05-23 19
E-Mail: info@rittal.de
www.rittal.de
HRA 6126 Wetzlar

ENCLOSURES

POWER DISTRIBUTION

CLIMATE CONTROL

IT INFRASTRUCTURE

SOFTWARE & SERVICES

FRIEDHELM LOH GROUP

