

CERTIFICATE

issued by

Rittal GmbH & Co. KG

Auf dem Stützelberg
D-35745 Herborn

Quality Management

Herewith we confirm that the Rittal AE enclosure

1001.600	1002.600	1002.500	1003.600	1004.600
1011.600	1005.600	1005.500	1006.600	1006.500
1009.600	1015.600	1007.600	1013.600	1008.600
1010.600	1010.500	1012.600	1014.600	1016.600
1017.600				

complies with the requirements of the hosedown test according to UL50 Type 4X (NEMA 4X) and fulfil the protection category IP66 according to EN 60529 "Degrees of protection provided by enclosures" dated September 2000.

Herborn, 2013-10-18


Axel Remmert
Quality Management Laboratory



Rittal's test laboratory is accredited with the German Accreditation Council (DAkkS) No. D-PL-17086-01-01 and Underwriters Laboratories Inc.

Rittal GmbH & Co. KG
Personally liable:
Rittal Management GmbH,
Schwende

Management:
Friedhelm Loh (President)
Karl Christoph Caselitz
Dr. Thomas Steffen
Hermann Tetzner
Michael Weiher

Rittal GmbH & Co. KG
Auf dem Stützelberg
D-35745 Herborn
Phone: +49(0)27 72 5 05-0
Fax: +49(0)27 72 5 05-23 19
E-Mail: info@rittal.de
www.rittal.de
HRA 6126 Wetzlar

ENCLOSURES

POWER DISTRIBUTION

CLIMATE CONTROL

IT INFRASTRUCTURE

SOFTWARE & SERVICES

FRIEDHELM LOH GROUP

