



Product Service

# CERTIFICATE

No. Z2 15 07 12010 007

**Holder of Certificate:** Rittal GmbH & Co. KG

Auf dem Stützelberg  
35745 Herborn  
GERMANY



**Certification Mark:**



**Product:** Switchgear Cabinets

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition the certification holder must not transfer the certificate to third parties. See also notes overleaf.

**Test report no.:** 713066501

**Valid until:** 2020-07-26

**Date,** 2015-08-11  
Page 1 of 2

( Horst Kristen )



**CERTIFICATE****No. Z2 15 07 12010 007****Model(s):****Type tested cabinets, empty enclosures  
Series AE, AE-EMV, CP-AE  
CP-AE with Tableau-Front  
KL, E-Box EB, Bus-Enclosure BG****Parameters:**

series:	AE, AE-EMV, CP-AE CP-AE with Tableau-Front
prot. degree:	IP 55 two door Version IP 55 one door Version Mod.1032/1035 IP 66 one door version IP 55 at CP-AE IP 54 at CP-AE with Tableau-Front
material:	series AE sheet steel, stainless steel series AL-EMV, AlZn coated
wall thickness:	enclosure 1,2 - 1,5 mm door 1,2 - 3,0 mm
dimensions:	200 x 300 x 120 mm to 1400 x 1600 x 400 mm
series:	KL, E-Box EB, Bus-Enclosure BG
prot. degree:	IP 66 KL without flange IP 55 KL with flange IP 66 E-Box IP 66 BG sheet steel without observation glass and stainless steel IP 65 BG sheet steel with obser. glass
material:	series KL without flange, sheet steel / stainless steel series KL with flange, sheet steel / stainless steel series BG, sheet steel / stainless steel series EB, sheet steel / stainless steel
wall thickness:	enclosure 1,2 - 1,5 mm cover / door 1,2 - 1,5 mm
dimensions:	150 x 150 x 80 mm to 1000 x 600 x 160 mm

**Tested  
according to:**EN 62208:2011  
IEC 62208:2011  
DIN EN 62208:2012**Production  
Facility(ies):**

12010, 17037, 44957, 47487

Page 2 of 2