

# CERTIFICATE

issued by

## Rittal GmbH & Co. KG

Auf dem Stützelberg  
D-35745 Herborn

Quality Management

Hereby we confirm that the Rittal Fould-out tray for keyboard and mouse - SZ 2379.600 and SZ 2379.800 - subject to correct mounting, complies with the protection category IP 55 according to EN 60529 „Degrees of protection provided by enclosures“ dated September 2014.

Hiermit bestätigen wir, dass die Rittal Tastatur-Klapplade SZ 2379.600 und 2379.800, bei sachgerechter Montage, die Schutzart IP 55 gemäß EN 60529 Ausgabe September 2014 „Schutzarten durch Gehäuse“ erfüllen.

Herborn, 2015-09-28

  
Axel Remmert  
Quality Management Laboratory



Rittal's test laboratory is accredited with the German Accreditation Council (DAKKS) No. D-PL-17086-01-00 and Underwriters Laboratories Inc.

Rittal GmbH & Co. KG  
Personally liable:  
Rittal Management GmbH,  
Schwende

Management:  
Friedhelm Loh (President)  
Hans Sondermann  
Dr. Thomas Steffen  
Hermann Tetzner  
Michael Weiher

Rittal GmbH & Co. KG  
Auf dem Stützelberg  
D-35745 Herborn  
Phone: +49(0)27 72 5 05-0  
Fax: +49(0)27 72 5 05-23 19  
E-Mail: info@rittal.de  
www.rittal.de  
HRA 6126 Wetzlar

ENCLOSURES

POWER DISTRIBUTION

CLIMATE CONTROL

IT INFRASTRUCTURE

SOFTWARE & SERVICES

