



Product Service

# CERTIFICATE

No. Z2 16 03 12010 015

**Holder of Certificate:** Rittal GmbH & Co. KG

Auf dem Stützelberg  
35745 Herborn  
GERMANY

**Production Facility(ies):**

17036, 44957, 47487

**Certification Mark:**



**Product:**

**Switchgear Cabinets**

**Model(s):**

**Type tested cabinets, empty enclosures  
Series TS 8**

**Parameters:**

protec. degree:	IP 55	IP 66
	sheet steel	sheet steel
	or stainless steel	or stainless steel
wall thickness:	enclosure 1,2-3,5 mm	enclosure 1,2-3,5 mm
	door 1,2-3,5 mm	door 1,2-3,5 mm
dimensions:	400 x 600 x 400 mm -	400 x 600 x 400 mm -
	1800 x 2400 x 1200 mm	800 x 2000 x 600 mm

**Tested according to:**

EN 62208:2011  
IEC 62208:2011  
DIN EN 62208:2012

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition the certification holder must not transfer the certificate to third parties. See also notes overleaf.

**Test report no.:**

713066503

**Valid until:**

2021-03-28

**Date,** 2016-03-29

( Horst Kristen )

Page 1 of 1

