

Certificate of Compliance

Certificate Number 20110114 – E170282
Report Reference E170282, 2000 September 11
Issue Date 2011 January 14

Page 1 of 1



Issued to: **RITTAL CORP**
1 RITTAL PL
SPRINGFIELD, OH 45504 USA

This is to certify that representative samples of

Industrial Control Panels

Model Descriptions: Industrial control panel enclosures, TS8 Series, DK-TS, TS8 3- Door FMDC and SV-TS8.

Have been investigated by Underwriters Laboratories Inc.® in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety:

The basic standards used to investigate products in this category are UL 508A, "Industrial Control Panels" and CSA-C22.2 No. 14, "Industrial Control Equipment."

Additional Information:

Rating:

Type 3R	TS8 (including stainless steel)
Maximum Height	2200 mm
Maximum Width (Single door)	1000 mm
Maximum Depth	800 mm
Maximum Height (Double door)	2000 mm
Maximum Width (Double door)	1800 mm

Only those products bearing the UL Listing Mark for the US and Canada should be considered as being covered by UL's Listing and Follow-Up Service meeting the appropriate requirements for US and Canada.

The UL Listing Mark for the US and Canada generally includes: the UL in a circle symbol with "C" and "US" identifiers:  the word "LISTED"; a control number (may be alphanumeric) assigned by UL; and the product category name (product identifier) as indicated in the appropriate UL Directory.

Look for the UL Listing Mark on the product

William R. Carney
Director, North American Certification Programs

Underwriters Laboratories Inc.

Any information and documentation involving UL Mark services are provided on behalf of Underwriters Laboratories Inc. (UL) or any authorized licensee of UL.

For questions, please contact a local UL Customer Service Representative at <http://www.ul.com/global/eng/pages/corporate/contactus/>