

Certificate of Compliance

Certificate Number 20090226 – E170282
Report Reference E170282, 1995 August 29
Issue Date 2009 February 26

Page 1 of 2



**Underwriters
Laboratories Inc.®**

Issued to: **RITTAL CORP**

1 RITTAL PL
SPRINGFIELD, OH 45504 USA

*This is to certify that
representative samples of*

Industrial Control Panels

Model Descriptions: Industrial Control Panel Enclosures, AE, WM and WMS Series.

Have been investigated by Underwriters Laboratories Inc.® in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety:

The basic standards used to investigate products in this category are UL 508A, "Industrial Control Panels" and CSA-C22.2 No. 14, "Industrial Control Equipment."

*Additional Information:
(Cont.)*

Ratings:

<u>Box Type</u>	<u>Max Dimensions (mm)</u>			<u>Environmental Type(s)</u>
	<u>Heig ht</u>	<u>Widt h</u>	<u>Dept h</u>	
AE - One Door	1500	1000	600	1, 12, 3R, 4
AE - Two Door	1500	1400	600	1, 12,
AE Stainless Steel - One Door	1500	1000	600	1, 12, 3R, 4, 4X
AE Stainless Steel - Two Door	1500	1400	600	1, 12
AE - EMC	1400	1400	600	1
AE - IVS	1400	1400	600	1, 12

The above devices may be provided with the following operators either mounted on the enclosure or with an empty cutout and a marking either on the enclosure or provided with the enclosure stating which operators are acceptable along with installation instructions.

Certificate of Compliance



**Underwriters
Laboratories Inc.®**

*Additional Information:
(Cont.)*

Ratings:

	Max Dimensions (mm)			Environmental
DK - AE	1400	1400	600	1, 12
*WM – One Door	1525	975	600	1, 3R, 4, 12
*WM – Two Door	1525	1525	600	1, 12
*WM Stainless Steel – One Door	1525	975	600	1, 3R, 4, 4X, 12
*WMS Stainless Steel – One Door	1525	975	600	1, 3R, 4, 4X, 12
*WM Stainless Steel – Two Door	1525	1525	600	1, 12

The above devices may be provided with the following operators either mounted on the enclosure or with an empty cutout and a marking either on the enclosure or provided with the enclosure stating which operators are acceptable along with installation instructions.

Only those products bearing the UL Listing Mark for the US and Canada should be considered as being covered by UL's Listing and Follow-Up Service meeting the appropriate requirements for US and Canada.

The UL Listing Mark for the US and Canada generally includes: the UL in a circle symbol with "C" and "US" identifiers:  the word "LISTED"; a control number (may be alphanumeric) assigned by UL; and the product category name (product identifier) as indicated in the appropriate UL Directory.

Look for the UL Listing Mark on the product

Issued by: *Jim Larin*

Jim Larin, Customer Service Specialist
Underwriters Laboratories Inc.

Reviewed by: *John Carrigan*

John Carrigan, Staff Engineer
Underwriters Laboratories Inc.

Any information and documentation involving UL Mark services are provided on behalf of Underwriters Laboratories Inc. (UL) or any authorized licensee of UL

For questions in The United States of America you may call 1-877-UL-HELPS.