

Certificate of Compliance

Certificate Number 20090608 – E170282
Report Reference E170282, 2001 March 30
Issue Date 2009 June 08

Page 1 of 1



**Underwriters
Laboratories Inc.®**

Issued to: **RITTAL CORP**
1 RITTAL PL
SPRINGFIELD, OH 45504 USA

*This is to certify that
representative samples of*

Industrial Control Panels

Model Descriptions: Industrial Control Panel Enclosures, Types EB, EB-EMC, EB-BUS, IE, JB, IN and BG/BH. Bus Housings may be designated either BG (German) or BH (English).

Standard(s) for Safety:


Have been investigated by Underwriters Laboratories Inc.® in accordance with the Standard(s) indicated on this Certificate.

The basic standards used to investigate products in this category are UL 508A, "Industrial Control Panels" and CSA-C22.2 No. 14, "Industrial Control Equipment."

Additional Information:

Ratings: All enclosures are rated Type 1, 3R, 4 and 12. Enclosures without openings, manufactured from Type 304 or 316 SS stainless steel are additionally rated Type 4X.

Only those products bearing the UL Listing Mark for the US and Canada should be considered as being covered by UL's Listing and Follow-Up Service meeting the appropriate requirements for US and Canada.

The UL Listing Mark for the US and Canada generally includes: the UL in a circle symbol with "C" and "US" identifiers:  the word "LISTED"; a control number (may be alphanumeric) assigned by UL; and the product category name (product identifier) as indicated in the appropriate UL Directory.

Look for the UL Listing Mark on the product

Issued by:

Jim Larin

Jim Larin, Customer Service Specialist

Underwriters Laboratories Inc.

Reviewed by:

John Carrigan

John Carrigan, Staff Engineer

Underwriters Laboratories Inc.

Any information and documentation involving UL Mark services are provided on behalf of Underwriters Laboratories Inc. (UL) or any authorized licensee of UL

For questions in The United States of America you may call 1-877-UL-HELPS.