



Certificate of Compliance

Certificate: 1672558

Master Contract: 153184

Project: 70000068

Date Issued: August 6, 2013

Issued to: Rittal GmbH & Co. KG
Auf dem Stuetzelberg 18
Herborn, 35745
Germany
Attention: Rüdiger Gilardi

The products listed below are eligible to bear the CSA Mark shown



Nitin Bhople

Issued by: Nitin Bhople

PRODUCTS

CLASS 1211 02 - COMFORT CONDITIONING EQUIPMENT - Air Conditioning Apparatus

Air conditioning apparatus, Series SK 3304, models SK3304.110, .114, .210, .510, .514 and SK 3304.610 rated 115 Vac, 60Hz, single phase; models SK3304.100, .104, .200, .500, .504 and SK 3304.600 rated 230 Vac, 60Hz, single phase, and models SK3304.030, .140, .144, .240, .540, .544, and SK 3304.640 rated 460Vac, 60Hz, three phase. All with refrigerant R-134a, Design pressure 406 psig.

Notes:

Notes (1): The air conditioning equipment to be used as a component part of another equipment, to cool electronic or mechanical components inside an electrical (enclosure) cabinet. The air conditioning unit, maintain a cabinet to a set temperature between 20°C to 55 °C. The unit will be operated within a maximum outdoor temperature ambient up to 55°C

APPLICABLE REQUIREMENTS

CAN/CSA-C22.2 No. 236-11 - Heating and Cooling Equipment