



Certificate of Compliance

Certificate: 1768404

Master Contract: 153184

Project: 70000086

Date Issued: June 27, 2013

Issued to: **Rittal GmbH & Co. KG**
Auf dem Stuetzelberg 18
Herborn, 35745
Germany
Attention: Rüdiger Gilardi

The products listed below are eligible to bear the CSA Mark shown



Nitin Bhople

Issued by: Nitin Bhople

PRODUCTS

CLASS 1211 02 - COMFORT CONDITIONING EQUIPMENT - Air Conditioning
Apparatus

Air conditioning apparatus, for use with enclosures, Series SK 3382 , models SK3382.110, .210, .510 and SK 3382.610 rated 115 V, 60Hz, single phase; models SK3382.100, .200, .500 and SK 3382.600 rated 230 V, 60Hz , single phase. All with Refrigerant R-134a, design pressure 406 psig.

Notes:

Notes (1): The air conditioning equipment to be used as a component part of another equipment, to cool electronic or mechanical components inside an electrical (enclosure) cabinet. The air conditioning unit, maintain a cabinet to a set temperature between 20°C to 55 °C. The unit will be operated within a maximum outdoor temperature ambient up to 55°C.

APPLICABLE REQUIREMENTS

CAN/CSA-C22.2 No. 236-11 - Heating and Cooling Equipment