

Certificate of Compliance

Certificate: 1695563 Master Contract: 153184

Project: 70002203 Date Issued: September 6, 2013

Issued to: Rittal GmbH & Co. KG

Auf dem Stuetzelberg 18

Herborn, 35745

Germany

Attention: Rüdiger Gilardi

The products listed below are eligible to bear the CSA Mark shown



Nitin Bhople

Issued by: Nitin Bhople

PRODUCTS

CLASS 1211 02 - COMFORT CONDITIONING EQUIPMENT - Air Conditioning Apparatus

Air conditioning apparatus, Series SK 3384, models SK3384.110, .210, .510 and SK 3384.610 rated 115 V, 60Hz, single phase; models SK3384.100, .200, .500 and SK 3384.600 rated 230 V,60Hz, single phase; models SK3384.140, .240, .540, and SK 3384.640 rated 400Vac,60Hz, two phase, and models SK3384.142,.146, 542,.546 rated 460V, 60Hz, 2 phase.

Notes:

Notes (1): The air conditioning equipment to be used as a component part of another equipment, to cool electronic or mechanical components inside an electrical (enclosure) cabinet. The air conditioning unit, maintain a cabinet to a set temperature between 20°C to 55 °C. The unit will be operated within a maximum outdoor temperature ambient up to 55°C

APPLICABLE REQUIREMENTS

CAN/CSA-C22.2 No. 236-11 - Heating and Cooling Equipment

DQD 507 Rev. 2012-05-22 Page: 1