

CERTIFICATE OF COMPLIANCE

Certificate Number 20130516-SA8250
Report Reference SA8250-20021106
Issue Date 2013-MAY-16

Issued to: RITTAL GMBH & CO KG
AUF DEM STUETZELBERG, 35745 HERBORN
GERMANY

**This is to certify that
representative samples of**



COMPONENT - AIR CONDITIONERS, SPECIAL
PURPOSE
REFER TO ADDENDUM PAGE FOR MODELS

Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.

Standard(s) for Safety: UL 484, Standard for Room Air conditioners
CSA C22.2 No.236, Standard for Heating and Cooling
Equipment

Additional Information: See the UL Online Certifications Directory at
www.ul.com/database for additional information

Only those products bearing the UL Recognized Component Marks for the U.S. and Canada should be considered as being covered by UL's Recognition and Follow-Up Service and meeting the appropriate U.S. and Canadian requirements.

The UL Recognized Component Mark for the U.S. generally consists of the manufacturer's identification and catalog number, model number or other product designation as specified under "Marking" for the particular Recognition as published in the appropriate UL Directory. As a supplementary means of identifying products that have been produced under UL's Component Recognition Program, UL's Recognized Component Mark: , may be used in conjunction with the required Recognized Marks. The Recognized Component Mark is required when specified in the UL Directory preceding the recognitions or under "Markings" for the individual recognitions. The UL Recognized Component Mark for Canada consists of the UL Recognized Mark for Canada:  and the manufacturer's identification and catalog number, model number or other product designation as specified under "Marking" for the particular Recognition as published in the appropriate UL Directory.

Recognized components are incomplete in certain constructional features or restricted in performance capabilities and are intended for use as components of complete equipment submitted for investigation rather than for direct separate installation in the field. The final acceptance of the component is dependent upon its installation and use in complete equipment submitted to UL LLC.

Look for the UL Recognized Component Mark on the product.



William R. Carney, Director, North American Certification Programs
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at www.ul.com/contactus



CERTIFICATE OF COMPLIANCE

Certificate Number 20130516-SA8250
Report Reference SA8250-20021106
Issue Date 2013-MAY-16

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

USR, CNR Component – Special purpose type room air conditioner
Models SK3305.100, SK3305.101, SK3305.104, SK3305.110, SK3305.111, SK3305.114, SK3305.120, SK3305.140, SK3305.141, SK3305.144, SK3305.200, SK3305.210, SK3305.240, SK3305.400, SK3305.440, SK3305.500, SK3305.501, SK3305.504, SK3305.510, SK3305.511, SK3305.514, SK3305.520, SK3305.540, SK3305.541, SK3305.542, SK3305.544, SK3305.600, SK3305.610, SK3305.640

Models SK3305.200, SK3305.210, SK3305.240 are identical to Models SK3305.100, SK3305.110, SK3305.140 respectively, except enclosure made of Stainless Steel AISI 304 or AISI 316.

Models SK3305.101, SK3305.111, SK3305.141 are identical to Models SK3305.100, SK3305.110, SK3305.140 respectively except for the condensate heater described in Sec.Gen. item 100 instead of the one described in item 70-30.

Models SK3305.104, SK3305.114 and SK3305.144 are identical to Models SK3305.100, SK3305.110 and SK3305.140 respectively, except that the former employs a stainless steel enclosure and a NEMA 4X interface to the electrical enclosure.

Models SK3305.600, SK3305.610, SK3305.640 are identical to Models SK3305.500, SK3305.510, SK3305.540 respectively, except enclosure made of Stainless Steel AISI 304 or AISI 316.

Models SK3305.501, SK3305.511, SK3305.541 are identical to Models SK3305.500, SK3305.510, SK3305.540 respectively, except for the condensate heater described in Sec.Gen. item 100 instead of the one described in item 70-30.

Models SK3305.400, SK3305.440 are identical to Models SK3305.500, SK3305.540, respectively, except for the condenser which is nano coated.

Models SK3305.542 is identical to Model SK3305.540, except for thicker rubber mountings at the compressor and at the condenser and evaporator fan.

Models SK3305.504, SK3305.514 and SK3305.544 are identical to Models SK3305.500, SK3305.510 and SK3305.540 respectively, except that the former employs a stainless steel enclosure and a NEMA 4X interface to the electrical enclosure.



William R. Carney, Director, North American Certification Programs
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at www.ul.com/contactus

